



The outline slide has a blue-toned background with architectural and technical diagrams. The title 'OUTLINE' is at the top right. A horizontal line with the word 'SUDOE' is positioned below the title. The main content is a bulleted list of research topics:

- Context & Motivations
- SYNERGY Research Platform
- Research activities
 - Smart reconfigurable PV energy management
 - Predictive dynamic thermal simulation of a building
 - DC microgrid management: OPA project
- Conclusion

Logos for Université Toulouse III - Paul Sabatier and Interreg Sudoe are at the bottom.

Climate Change Challenges




• Horizon 2020:

- 20% greenhouse gas reduction,
- 20% energy efficiency improvement,
- 20% increase of renewable energies.

• Horizon 2030:

- 40% greenhouse gas reduction,
- 30% energy efficiency improvement,
- 27% increase of renewable energies.

LAAS CNRS

SUDOE


UNIVERSITÉ TOULOUSE III PAUL SABATIER

INTERREG Sudoe TR@NSENER

From Today's Power System to Smart Grid

Internet of Energy: merging Internet and Energy grid networks

- Bi-directional communication of data and energy




Third Industrial Revolution

LAAS CNRS

SUDOE

UNIVERSITÉ TOULOUSE III PAUL SABATIER TUCS

INTERREG Sudoe TR@NSENER



**LAAS
CNRS**

Building Modularity

UNIVERSITÉ TOULOUSE III PAUL SABATIER

LAAS-CNRS Interreg Sudoe TR@NSENER

**LAAS
CNRS**

SYNERGY Research Platform

- **100kWp photovoltaics**
- **Geothermics:**
 - Canadian well
 - Vertical Geothermics
 - Heat pumps (3)
- **Storage:**
 - Lead Batteries (59kWh)
 - Li-ion Batteries (56kWh)
 - Supercapacitors (286Wh)
- **Three supervision systems:**
 - Lighting, Ambient Temperature Control, Energy production/consumption

UNIVERSITÉ TOULOUSE III PAUL SABATIER

SUDOE

Characterization platform

Interreg Sudoe TR@NSENER

LAAS CNRS

Supervision System

SUDOE

- **Heating, Ventilation, Air Conditioning**
 - 650 points of measurement and regulation
- **Lighting:** 3700 measurement points
 - Movement detection and illumination sensors
 - Power adjusted according to ambient light level
 - Setting of time slots / operation by zone
- **Electricity:** 500 data collected
 - Detailed power consumption (zone, usage...)
 - Energy production (photovoltaic, geothermics)
 - Correlation to environmental/ambient measurement

UNIVERSITÉ TOULOUSE III PAUL SABATIER

9

Interreg Sudoe TR@NSENER

LAAS CNRS

Real-time monitoring of PV production/consumption

CNS Administrateur

SNEF

Panorama

Toiture

Bandage

Terrasse

Verrière Tri-Vitre

Verrière Bi-Vitre

Station météo

0.0 °C N 1.4 m/s

0.0 %Hr

986.4 mBar 594.6 W/m²

Date: 26/03/13 15:47:41

Événement: Avertissement alarme sonore

Libellé: Débit de Communication

Equipement: Débit de Communication

Code: 00000000000000000000000000000000

CONSIGNATIONS ALARMES

Réseau EDF

12813 W 24000Wc

7847 W 19200Wc

10600 W 18190Wc

12386 W 20114Wc

4709 W 15569Wc

52022 W 46436 W

Synthèse production:

Puissance: 46436 W

Energie Totale: 101.76 MWh

CO₂ Evités : 9.04 Tonnes

UNIVERSITÉ TOULOUSE III PAUL SABATIER TUCS

Interreg Sudoe TR@NSENER

LAAS CNRS

SYNERGY: SYstems for smart eNERGY management

Objectives:

Providing key original building blocks and a global approach for smart energy management – from microsystems to smart grid

Three main topics:

- Efficient energy generation and processing
- Integration of renewable energies
- Smart energy management
 - Internet of energy

Components & Systems

Advanced Modeling

Interreg Sudoe TR@NSENER

LAAS CNRS

OUTLINE

- Research activities
 - Smart reconfigurable PV energy management
 - Predictive dynamic thermal simulation of a building
 - DC microgrid management: OPA project

Interreg Sudoe TR@NSENER

Impact of Defects on PV Performance

Gain power electronics in a PV installation (NREL LAB)

Type of mismatch	Losses	Gain DC-DC
Shadow residential roof, one-string	5-15%	+15-20% of the losses
Shadow residential roof, multi-string	5-20%	+20-30% of the losses
Commercial system	1-5%	+ 30-40% of the losses
Orientation mismatch	5-20%	+100% of the losses
I_{opt} mismatch	0.2-1%	+100% of the losses
Soiling	1.5-6.2%	+15-40% of the losses

LAAS- TOTAL SA Collaboration
PhD of Youssef EL BASRI

Interreg Sudoe TR@NSE13-R

Contact: Corinne Alonso

UNIVERSITÉ TOULOUSE III PAUL SABATIER

Smart Reconfigurable PV Energy Management

Shading evolution over time

Speed of shadow 30 cm/h

Photovoltaic system under shading condition

Power [W]

Current [A]

V_{opt} [V]

Time

Chimney

6 PV Modules

Shadow

Partial shading

Uniform shading

LAAS CNRS

UNIVERSITÉ TOULOUSE III PAUL SABATIER TUCS

Interreg Sudoe TR@NSE14

LAAS CNRS

Smart Reconfigurable PV Energy Management

Mitigating the detrimental effects of partial shading

The diagram illustrates a smart reconfigurable PV energy management system. It features a grid of solar panels connected to a central control unit. The control unit manages serial and parallel switches to bypass shaded panels. MPPT converters connect the panels to a load. Three architectures are compared: w/o Bypass, With Bypass, and Distributed. A graph shows power output over time for each case.

Type of architecture	Energy	Gain (%)
Without Bypass	374Wh	
With Bypass	468Wh	
Distributed	507Wh	10.4%

Sudoe TR@NSENER

LAAS CNRS

OUTLINE

• Research activities

- Smart reconfigurable PV energy management
- Predictive dynamic thermal simulation of a building
- DC microgrid management: OPA project

Interreg Sudoe TR@NSENER

LAAS CNRS

Energy Transition & Buildings

SUDOE

- 43% primary energy consumption
- 4/5 for thermal purposes (heating, cooling, sanitary water, cooking)
- **Very slow evolutions:** each year total of new buildings represents 1% of existing ones and demolitions 0,1%
- **Ambitious political actions** needed to speed up this evolution

UNIVERSITÉ TOULOUSE III PAUL SABATIER

Interreg Sudoe TR@NSENER

LAAS CNRS

Predictive Dynamic Thermal Simulation of a Building

SUDOE

Objectives: optimization of the power consumption of the building for better energy efficiency

PRODUCTION

- Photovoltaics
- Geothermics



CONSUMPTION

- HVAC
- Electronic equipment
- Lighting

- Development of accurate and compact models
 - Model reduction
 - Identification of relevant input and output data for each model
 - Calibration of models against measured data
 - Prediction of electric power consumption of systems
 - Improvement of thermal regulation according to real-time electricity production

Contact: Bruno Estibals

UNIVERSITÉ TOULOUSE III PAUL SABATIER

Interreg Sudoe TR@NSENER

Predictive Dynamic Thermal Modeling of a Building

3D Model of ADREAM building

Consumption Source	Real Consumptions [MWh/an]	Simulated Consumptions [MWh/an]	Relative Error [%]
Heat Pump 1	9,03		
Heat Pump 2	16,71	35,41	
Heat Pump 3	9,67		
Air Handling Unit		17,79	
Distribution Pumps	69,64	63,63	8,63
Electronic Equipment	65,77	63,43	3,56
Lighting	12,03	11,89	1,16
TOTAL	200,64	192,88	3,82

Objective

Drastically reduce power consumption by at least 20%

Interreg Sudoe TR@NSENER


Predictive Dynamic Thermal Modeling of a Building

```

    graph LR
        PS[powersimu] -- Signal of the Compressor --> R[Relay]
        R --> P1[Plot 1]
        TS[returnsimu] -- Temperature Return Data --> CP2[Comparison Plot 2]
        R --> HP[ss2 Heat Pump Model]
        HP -- T_Depart --> WP[watersimu]
        WP -- Temperature Depart Data --> CP1[Comparison Plot 1]
        HP -- T_Retour --> BM[Building Model]
        BM --> TS
        CP1 --> CP2
    
```

Simulation of the heat pump and control with Simulink

Interreg Sudoe TR@NSENER



LAAS CNRS

DC Distribution Advantages

SUDOE

- Most of *renewable energies* (PV, fuel cell, wind turbine) provide DC power
- Many *electronic equipment* (computers, LED lighting, smart phones, EV) operate under DC power supply
- Easier control compared to AC: *only voltage*
- *Connection of AC grids* with different frequencies
- *Reduced losses* over long-distance
- *Higher efficiency* than AC microgrid
- *Higher reliability*
- *Space and cost savings*



UNIVERSITÉ TOULOUSE III PAUL SABATIER


Interreg Sudoe TR@NSENER

LAAS CNRS

DC Microgrid: application to data centers

SUDOE

- In California, ~ **7.1 TWh/year*** are consumed by UPS (Uninterruptible Power Supply) that operate two conversions : AC/DC and DC/AC.








- DC microgrid: **7 to 28 %**** expected power consumption reduction



* Fortenberry, Brian, Ecos Consulting EPRI, and William Tschudi. DC power for improved data center efficiency. (2008)
 ** Affolter, J. F., B. Chappuis, and L. Rigazzi. Réseaux de distribution basse tension en courant continu. Bulletin SEV/VSE (2014): 39-44.



UNIVERSITÉ TOULOUSE III PAUL SABATIER

Interreg Sudoe TR@NSENER









LAAS CNRS

OPA: Open Data Syndream Platform

- <https://syndream.laas.fr/>



The screenshot shows the OPA Project website. At the top, there's a banner with a willow tree and solar panels. Below it is a "Latest news" section with a message about the website being online since Sept. 27, 2016. The main content area is divided into three main sections: "Project" (with a video thumbnail), "Open Data" (with a "OPEN DATA" button), and "Open Services" (with a "INTERACT" button). A note at the bottom of the Open Data section states that datasets will be limited if not logged in.


LAAS CNRS

OPA: Open Data Syndream Platform

- <https://syndream.laas.fr/>

This screenshot focuses on the "Open Data" section of the website. It features a large image of a building with a solar panel roof. To the right is a search interface for datasets, showing 253 datasets in total. The search bar contains placeholder text "E.g., photovoltaic, day, iso1". Below the search bar are buttons for "Advanced search" and "Help page". A note at the bottom of the search interface states that datasets will be limited if not logged in. The footer includes logos for Université Toulouse III - Paul Sabatier, Interreg Sudoe TR@NSENER, and the European Union.





Acknowledgments: C. Alonso, C. Artigues, K. Drira, C. Ecrepont, B. Estibals, N. Guermouche, T. Guérout, B. Jammes, Y. Labit, S. Medjiah, S. Ngueveu, P. Lopez, L. Séguier, S. Taizi.
PhD & post doc students: F. Aissaoui, A. Barroso, Y. El Basri, C. Bazile, I. De Courcelle, J. Dulout, G. Garzone, G. Gharbi, A. Guttierrez, K. Neuhaus, I. Papas, N. Seydoux.